



ИБП Eaton 5P 1150i Rack1U (5P1150iR) - Eaton 5P 1150 IEC CB Test Certificate

Постоянная ссылка на страницу: <https://eaton-power.ru/catalog/eaton-5p/eaton-5p-1150i-stoyka-1u/>



Ref. Certif. No.

JPTUV-049612

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Uninterruptible Power Supply

Name and address of the applicant
Nom et adresse du demandeur

LianZheng Electronic (ShenZhen) Co., Ltd.
No.4 Liufang Rd, Block 67
Baoan, Shenzhen, Guangdong, P.R. China

Name and address of the manufacturer
Nom et adresse du fabricant

Eaton Industries France
110 rue Blaise Pascal
38330 Montbonnot Saint Martin, France

Name and address of the factory
Nom et adresse de l'usine

LianZheng Electronic (ShenZhen) Co., Ltd.
No.4 Liufang Rd, Block 67
Baoan, Shenzhen, Guangdong, P.R. China

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input : AC 200-240V; 50/60Hz; 7.1A Max ; Class I; 1ø
Output: AC 200-240V; 50/60Hz; 1ø
AC 200-208V; 1395VA/990W/7.0A
AC 220-240V; 1550VA/1100W/7.1A

Trademark (if any)
Marque de fabrique (si elle existe)

Eaton

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

N/A

Model / Type Ref.
Ref. de type

5P1550i, 5P1550G, 5P1550iR 5P1550GR 5P1550AU

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page)

For model differences, refer to the test report.

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 62040-1:2008
National differences see test report

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

17030708 001

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021 Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web: www.tuv.com

Date: 26.02.2013

Signature:

Dipl.-Ing. (FH) C. Nasca



Test Report issued under the responsibility of:



TEST REPORT IEC 62040-1 Uninterruptible power systems (UPS) – Part 1: General and safety requirements for UPS	
Report Reference No.	17030708 001
Date of issue	Feb. 26, 2013
Total number of pages	53
CB Testing Laboratory	TÜV Rheinland (Shenzhen) Co., Ltd.
Address	3&4 F, Cybio Technology Building No. 1, Langshan No. 2 Road South, 5th Industrial Area, High-Tech Industry Park North, Nanshan District, 518057 Shenzhen, P.R. China
Applicant's name	LianZheng Electronic (ShenZhen) Co., Ltd
Address	No. 4 Liufang Rd, Block 67 Baoan, Shenzhen, Guangdong, P.R. China
Test specification:	
Standard	IEC 62040-1 : 2008 (1st Edition)
Test procedure	CB
Non-standard test method.....	N/A
Test Report Form No.	IEC62040_1A
Test Report Form(s) Originator	TÜV Rheinland Japan Ltd.
Master TRF	Dated 2009-11
Copyright © 2009 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
Test item description	Uninterruptible Power Supply
Trade Mark	Eaton
Manufacturer	Eaton Industries France
Address	110 rue Blaise Pascal 38330 Montbonnot Saint Martin
Model/Type reference	5P1550i, 5P1550G, 5P1550iR 5P1550GR 5P1550AU
Ratings	For all models Input: 200-240Vac, 50/60Hz, 1Ø, 7.1A max Output: 200-240Vac, 50/60Hz, 1Ø 200-208Vac: 1395VA/990W/7.0A 220-240Vac: 1550VA/1100W/7.1A