



ИБП Eaton 5P - Eaton 5P 850-1150 IEC CB Test Certificate

Постоянная ссылка на страницу: <https://eaton-power.ru/catalog/tower/eaton-5p/>



Ref. Certif. No.

JPTUV-049604

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
Produit

Uninterruptible Power Supply

Name and address of the applicant  
Nom et adresse du demandeurLianZheng Electronic (ShenZhen) Co., Ltd.  
No.4 Liufang Rd, Block 67  
Baoan, Shenzhen, Guangdong, P.R. ChinaName and address of the manufacturer  
Nom et adresse du fabricantEaton Industries France  
110 rue Blaise Pascal  
38330 Montbonnot Saint Martin, FranceName and address of the factory  
Nom et adresse de l'usineLianZheng Electronic (ShenZhen) Co., Ltd.  
No.4 Liufang Rd, Block 67  
Baoan, Shenzhen, Guangdong, P.R. ChinaRatings and principal characteristics  
Valeurs nominales et caractéristiques principalesInput : AC 200-240V; 50/60Hz; 3 9A Max.; Class I; 1ø  
Output: AC 200-240V; 50/60Hz; 1ø  
AC 200-208V; 1)765VA/540W/3 9A; 2)10355VA/693W/5 2A  
AC 220-208V; 1)850VA/600W/3 9A; 2)1150VA/770W/5.3ATrademark (if any)  
Marque de fabrique (si elle existe)

Eaton

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

N/A

Model / Type Ref.  
Ref. de type1)5P850i, 5P850iR, 5P850AU, 5P850GR  
2)5P1150i, 5P1150iR, 5P1150AUAdditional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,  
peuvent être indiqués sur la 2<sup>ème</sup> page)

For model differences, refer to the test report.

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à laIEC 62040-1:2008  
National differences see test reportAs shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

17030707 001

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationTUV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021 Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web: www.tuv.com

Date: 26.02.2013

Signature:

Dipl.-Ing. (FH) C. Nasca



Test Report issued under the responsibility of:



<b>TEST REPORT</b> <b>IEC 62040-1</b> <b>Uninterruptible power systems (UPS) –</b> <b>Part 1: General and safety requirements for UPS</b>	
Report Reference No. ....	17030707 001
Date of issue.....	Feb. 26, 2013
Total number of pages.....	60
CB Testing Laboratory.....	TÜV Rheinland (Shenzhen) Co., Ltd.
Address .....	3&4 F, Cybio Technology Building No. 1, Langshan No. 2 Road South, 5th Industrial Area, High-Tech Industry Park North, Nanshan District, 518057 Shenzhen, P.R. China
Applicant's name.....	LianZheng Electronic (ShenZhen) Co., Ltd
Address .....	No. 4 Liufang Rd, Block 67 Baoan, Shenzhen, Guangdong, P.R. China
<b>Test specification:</b>	
Standard.....	IEC 62040-1 : 2008 (1st Edition)
Test procedure .....	CB
Non-standard test method.....	N/A
Test Report Form No. ....	IEC62040_1A
Test Report Form(s) Originator.....	TÜV Rheinland Japan Ltd.
Master TRF.....	Dated 2009-11
<b>Copyright © 2009 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	

**Test item description**..... : **Uninterruptible Power Supply**  
Trade Mark ..... : Eaton  
**Manufacturer** ..... : **Eaton Industries France**  
Address ..... : 110 rue Blaise Pascal 38330 Montbonnot Saint Martin  
Model/Type reference..... : 5P850i, 5P850iR, 5P850AU, 5P850GR, 5P1150i, 5P1150iR,  
5P1150AU  
Ratings ..... : For 5P850i, 5P850iR, 5P850AU, 5P850GR  
Input: 200-240Vac, 50/60Hz, 1Ø, 3.9A max  
Output: 200-240Vac, 50/60Hz, 1Ø  
200-208Vac: 765VA/540W/3.9A  
220-240Vac: 850VA/600W/3.9A  
For 5P1150i, 5P1150iR, 5P1150AU  
Input: 200-240Vac, 50/60Hz, 1Ø, 5.3A max  
Output: 200-240Vac, 50/60Hz, 1Ø  
200-208Vac: 10355VA/693W/5.2A  
220-240Vac: 1150VA/770W/5.3A